Multi-Objective Optimal Sizing for Battery Storage of PV-Based Microgrid with Demand Response

Authors:

Nan Zhou, Nian Liu, Jianhua Zhang, Jinyong Lei

Date Submitted: 2019-01-07

Keywords: non-dominated sorting genetic algorithm II (NSGA-II) algorithm, multi-objective optimization, investment and benefit model, photovoltaic consumptive rate, battery energy storage system (BESS), multi-period demand response (DR), time-of-use (TOU) price

Abstract:

In order to solve the influence of uncertain photovoltaic power (PV) on the stable operation of microgrid (MG), demand response (DR) and battery energy storage system (BESS) need to be introduced simultaneously into the operation optimal scheduling of PV-based microgrid (PV-MG). Therefore, it is of great significance for commercial investment decisions of PV-MG to consider the influence of DR on BESS optimal sizing. Under the peak-valley time-of-use (TOU) price, this paper builds cross-time DR models based on price elasticity matrix. Furthermore, through the introduction of DR and BESS into PV-MG scheduling optimization, the MG investment and benefit model is proposed. Considering the constraint condition such as co-ordination of supply and demand, electricity price elasticity and energy loss of storage system, the improved non-dominated sorting genetic algorithm II (NSGA-II) is utilized to solve the multi-objective optimal allocation model of the BESS with the target of maximum PV consumptive rate and annual net profits. The optimization method was applied to a PV-MG in Guangdong. Through the regulation and control effect of demand response and BESS on load distribution, the uncertainties PV power can be suppressed so as to improve the PV system consumptive level, which is of great guiding significance for BESS optimal sizing under this situation.

Record Type: Published Article

Submitted To: LAPSE (Living Archive for Process Systems Engineering)

Citation (overall record, always the latest version): Citation (this specific file, latest version): Citation (this specific file, this version): LAPSE:2019.0098 LAPSE:2019.0098-1 LAPSE:2019.0098-1v1

DOI of Published Version: https://doi.org/10.3390/en9080591

License: Creative Commons Attribution 4.0 International (CC BY 4.0)



Article



Multi-Objective Optimal Sizing for Battery Storage of PV-Based Microgrid with Demand Response

Nan Zhou¹, Nian Liu^{1,*}, Jianhua Zhang¹ and Jinyong Lei²

- State Key Laboratory for Alternate Electrical Power System with Renewable Energy Sources, North China Electric Power University, Changping District, Beijing 102206, China; hycp.zn@gmail.com (N.Z.); zhangjianhu@ncepu.edu.cn (J.Z.)
- ² Electric Power Research Institute, China Southern Power Grid Co., Ltd., Guangzhou 510080, Guangdong Province, China; leijy@csg.cn (J.L.)
- * Correspondence: nianliu@ncepu.edu.cn; Tel.: +86-10-6177-3728

Academic Editor: Gabriele Grandi Received: 10 May 2016; Accepted: 19 July 2016; Published: 28 July 2016

Abstract: In order to solve the influence of uncertain photovoltaic power (PV) on the stable operation of microgrid (MG), demand response (DR) and battery energy storage system (BESS) need to be introduced simultaneously into the operation optimal scheduling of PV-based microgrid (PV-MG). Therefore, it is of great significance for commercial investment decisions of PV-MG to consider the influence of DR on BESS optimal sizing. Under the peak-valley time-of-use (TOU) price, this paper builds cross-time DR models based on price elasticity matrix. Furthermore, through the introduction of DR and BESS into PV-MG scheduling optimization, the MG investment and benefit model is proposed. Considering the constraint condition such as co-ordination of supply and demand, electricity price elasticity and energy loss of storage system, the improved non-dominated sorting genetic algorithm II (NSGA-II) is utilized to solve the multi-objective optimal allocation model of the BESS with the target of maximum PV consumptive rate and annual net profits. The optimization method was applied to a PV-MG in Guangdong. Through the regulation and control effect of demand response and BESS on load distribution, the uncertainties PV power can be suppressed so as to improve the PV system consumptive level, which is of great guiding significance for BESS optimal sizing under this situation.

Keywords: time-of-use (TOU) price; multi-period demand response (DR); battery energy storage system (BESS); photovoltaic consumptive rate; investment and benefit model; multi-objective optimization; non-dominated sorting genetic algorithm II (NSGA-II) algorithm

1. Introduction

In recent years, the energy crisis and deteriorating living environment have promoted the development of new energy resources. Compared with hydro, nuclear and wind power generation, photovoltaic power (PV) generation is less restricted by geography, resources, manufacturing materials and long-distance transmission. Thus, the PV industry has achieved rapid development. International Energy Agency (IEA) and the European Joint Research Centre (JRC) predicted that the global PV generation capacity would account for 2% of the total electricity power generation by 2020. This proportion will be even more than 10% by 2030.

The output power of PV generation is intermittent and random, which causes the difficulties and complexities of PV-based microgrid (PV-MG) [1]. As for the island PV-MG, particularly with high penetration of PV, there is the problem of power supply reliability. For grid-connected PV-MG, is the bulk power system fault will lead to off-network operation. Therefore, battery energy storage system (BESS) is necessary to smooth and stabilize its output, meet the load demand, and improve the

power quality. BESS has dual property of load and power resource. By virtue of flexible charge and discharge characteristics, BESS has prospects in smoothing and stabilizing the output of PV system, peak load shifting, operating reserve, improving power quality and scheduling flexibility of PV-MG. Therefore, optimal sizing of BESS with reasonable volume can significantly improve the efficiency of PV system and promote the local PV consumptive rate [2].

Currently, due to the high price of BESS devices, the optimal sizing of BESS capacity should not be too large, which could significantly increase investment cost. However, excessively small energy optimal sizing cannot guarantee the stable operation of PV-MG and promote PV power consumption. Therefore, the reasonable optimal sizing of BESS system in PV-MG has become one of the focus researches of many scholars. At present, research of BESS capacity optimization is mainly focused on: (1) BESS optimal sizing method under two scenarios of single and hybrid BESS systems [3,4]; (2) BESS optimal sizing principle under the off-grid and gird-connected operation of MG [5,6]; (3) BESS optimization analysis methods, such as the difference supplement method, fluctuation smoothing analysis method [7,8]; (4) for particular types of PV-MG, such as industrial and commercial MG, quantitative analysis is carried out on the economic benefits of BESS system optimal sizing [9,10]. [10] focused on the optimization of the capacities of components in the PV-based BSS (battery switch stations) with consideration of battery swapping requirement and maximally utilizing PV energy.

DR refers to the electricity consumers' response on power price signal or incentive mechanism to change the market participation behavior of normal power consumption mode, which is an important means in optimal operation of PV-MG. Research of Pacific Northwest National Laboratory indicated that, under the condition of the fluctuant electricity price, users would be willing to change their consumption behaviors and adjust the power consumption of controllable equipment. Demand response technology can be used to optimize the operation of MG [11,12], frequency and connection line power [13,14], as well as support emergency fault [15,16]. DR can significantly improve the economy, reliability and flexibility of MG system [17]. With the improvement of the electric power market and the widespread application of the communication, the load optimization of the demand response has become the important factor that can not be ignored in the MG's planning and operation. Therefore, it is needed to consider the influence of the demand response when the energy storage optimal sizing is carried out.

In the BESS optimal configuration, in order to clarify the benefits and advantages of the proposed model, the features are compared to several related papers [18–22], in terms of optimization objectives, constraints, solving algorithm, connected or disconnected to grid, whether the demand response factors are considered. The comparison result is shown in Table 1 below. With respect to the optimization objectives, most contrastive papers focus on one specific function of BESS, such as compensate for power fluctuations, while this paper proposes multi-objectives optimal model of maximum PV consumptive rate and annual net profits. As the basic data and scenarios in these papers are different, their simulation constraints and solving algorithms are not comparable. In addition, the proposed model introduces DR and BESS simultaneously into the operation optimal scheduling of grid-connected PV-MG, and has a relatively superior guiding significance for the commercial investment of BESS in PV-MG.

There are mainly two kinds of methods to analyze DR of users: one is fitting DR curve through historical data [23,24]; the other is by obtaining elastic matrix to analyze the response of users to the price change [25–27]. Since the latter is more suitable for quantitative analysis, it is widely used in the analysis of DR. [25] described how the consumers behavior can be modeled using a matrix of self and cross elasticity, and how elasticity can be taken into consideration when scheduling generation and setting the price of electricity in a pool based electricity market. [26] introduced the impact of price elasticity matrix of demand side on power purchase decision-making under time-of-use (TOU) price into the optimization of power supply company power purchase from weekly market. However, the elasticity coefficients in these papers are artificially given without calculation through reasonable method or model. [27] established multiple regression model of electricity consumption and price

based on the electricity market statistics, and analyzes the price elasticity of electricity demand by the difference between SD and control group LADWP. However, it only considers self-elasticity, not cross-elasticity. Given the BESS configuration is made at the planning stage of PV-MG, so it demands less on real-time performance and TOU is the most principle DR project implemented. Thus, this paper explores the DR's influence on BESS configuration under TOU price scenario.

Properties	[18]	[19]	[20]	[21]	[22]	This paper
Optimization	Compensate	Total cost of	Economic	Operation	Power	Maximum PV
objectives	for power	BESS	benefits of	cost	compensation	consumptive
	fluctuations		microgrid	minimization	to loads	rate and net
			(MG), user	of MG		profits of MG
			satisfaction			
Constraints	BESS	Frequency	BESS	Power	BESS	BESS
	physical	control	constraints,	capacity of	locations,	constraint,
	properties,	with load	energy	DG, BESS	frequency	operation
	operational	shedding	permeability,	operation,load	and voltage	boundary,
	boundary	scheme	Power	satisfaction	regulation	users expense
	-		transmission		0	-
Solving	Guideline	Particle	Combinatorial	Grey wolf	Artificial	Non-dominated
algorithm	and current	swarm	optimization	optimization	neural	sorting
	control	optimization	combining		network	genetic
	algorithm	-	with PSO		(ANN)	algorithm
	Ū.					II(NSGA-II)
Connected	Yes	No	Yes	Yes	Yes	Yes
to grid						
Demand	No	Yes	Yes	No	No	Yes
response						

Table 1.	Comparisor	with several	related pape	ers.
----------	------------	--------------	--------------	------

Based on the above analysis, this paper establishes multi-period DR model based on price elasticity matrix under TOU price and introduces DR and BESS system operation into PV-MG scheduling optimization to analyze the impact of DR on BESS optimal sizing, which is of significant effect on commercial investment decisions of PV-MG. The contribution mainly includes following aspects.

- (1) The multi-period DR model based on price elasticity matrix under TOU price is established, which can reflect the impact of TOU price on users' electricity consumption.
- (2) The DR and BESS system operation are included into PV-MG scheduling optimization to build the MG investment profit model, and the PV consumptive rate and annual net profits are taken as greatest objectives.
- (3) Considering the constraint conditions such as power supply and demand balance, side electricity price elasticity, loss of BESS systems, NSGA-II algorithm is utilized to solve the DR-based BESS capacity optimize optimal sizing model in PV-MG.

2. System Architecture of PV-Based Microgrid (PV-MG)

The System Architecture of PV-MG is shown as Figure 1. The demand side response resources in PV-MG mainly include four categories of PV resources, BESS resources, load resources and electricity price resources [28,29]. The PV-MG is connected to bulk power system at the point of common coupling (PCC), the electricity power generated in PV-MG is preferentially supplied to meet the local loads, and exchange electricity with the bulk power system if in need.



Figure 1. Typical structure of PV-based microgrid (PV-MG).

- (1) PV resource: PV power generation is considered as the renewable energy generation resources most suitable to popularized and applied in the user side [30]. PV system is composed of PV array and PV DC/AC inverters. According to the sunshine situation, PV system adopts maximum power point tracking (MPPT) to improve the solar efficiency as much as possible [31].
- (2) BESS resource: BESS in MG generally is mostly composed of lithium ion battery or lead acid battery system equipped with appropriate bidirectional DC/AC inverters. Its functions in PV-MG can be divided into two categories: one is power quality (PQ) mode, which cites out power adjustment in short time scale to meet the power quality requirements; the other is power shaving (PS) mode, which could meet the power output requirements in hour time scale [32]. The economic benefits considered in this paper mainly include PS mode of BESS, and the power adjustment of power adjustment in hour time scale.
- (3) Load resource: Load species is characterized by diversity. It is mainly divided into residential, commercial and industrial loads. Residential loads mainly include heating, ventilation and air conditioning (HVAC), refrigerator, water heater as well as other household appliances [33]. Commercial loads mainly include lighting, HVAC, office computers and other types of commercial appliances [34]. Industrial loads are dominated by long-term continuous loads concerning production process, such as machinery, electrolysis, and electric heating.
- (4) Electricity price resource: Electricity price generally includes TOU price, real time price, critical peak price, etc. This paper studies the impact of DR on BESS optimal sizing under TOU price [35].

During the operation of PV-MG, the four categories of demand side resources combine closely with each other. Therefore, the BESS capacity optimal sizing should not only consider the BESS and PV-MG operation strategy, the impact of electricity price and loads DR cannot be ignored, which can improve the actual operation adaptability of BESS optimal sizing.

3. Demand Response Model

DR projects include electricity price mechanism and compensation incentive mechanism, and both means change electricity consumption by price change or economic compensation. As a special commodity, the price change of electricity will affect consumption behaviour. When users participate in market electricity price response, the demand curve will be left oblique and bending, as shown in Figure 2.



Figure 2. Impact of demand response (DR) to market price.

[36] pointed out that, based on the balance of commodity supply and demand elasticity, commodity price and deal quantity (correspond to electricity price and electricity consumption separately in this paper) present linear relation near the electric power market equilibrium point. Its expression is

$$q = -a \cdot p + b \tag{1}$$

Based on the equilibrium relationship between commodity supply and elastic demand as well as the price elasticity matrix of electricity price in multi time period, the users' DR behaviors can be more accurately and comprehensively described under TOU price. Electricity price elasticity refers to the function relationship between electricity consumption change rate and electricity price change rate. The actual function expression of the typical demand curve usually needs to be considered in different factors for regression analysis. In order to simplify this complex process, it is treated as a linear function.

In practical, users will not only consider the electricity prices at current and other moments. Self-elasticity coefficient is utilized to express the impact of current moment electricity price change rate on current moment electricity consumption, while cross-elasticity coefficient means the impact that on the other moment electricity consumption. The formula for the relationship between the change rates the electricity quantity and electricity prices expressed in elasticity coefficient is as follows:

$$\varepsilon_{ii} = \frac{\Delta q_i / q_i}{\Delta p_i / p_i} \tag{2}$$

$$\varepsilon_{ij} = \frac{\Delta q_i / q_i}{\Delta p_j / p_j} \tag{3}$$

For time periods $1 \sim n$, the elastic matrix can be constructed as:

$$\begin{bmatrix} \Delta q_1/q_1 \\ \Delta q_2/q_2 \\ \dots \\ \Delta q_n/q_n \end{bmatrix} = \begin{bmatrix} \varepsilon_{11} & \varepsilon_{12} & \dots & \varepsilon_{1n} \\ \varepsilon_{21} & \varepsilon_{22} & \dots & \varepsilon_{2n} \\ \dots & \dots & \dots & \dots \\ \varepsilon_{n1} & \varepsilon_{n2} & \dots & \varepsilon_{nn} \end{bmatrix} \begin{bmatrix} \Delta p_1/p_1 \\ \Delta p_2/p_2 \\ \dots \\ \Delta p_n/p_n \end{bmatrix}$$
(4)

This paper takes the assumption in [37] that the elastic matrix is symmetrical to the y diagonal, which means electricity price has the same effect on electricity consumption between two time periods with the same distance.

$$\varepsilon_{ij} = \varepsilon_{ji} \tag{5}$$

Theoretically, the price tariff can be divided into single pricing, TOU pricing, real time pricing, critical peak pricing and so on, which can be implemented in the PV-MG and have influence on the BESS optimal sizing considering the demand response. Real time pricing is ideal instantaneous dynamic prices in space, which requires almost instantaneous match of price and cost in power grid, and users can't timely and effectively arrange their loads in the short term [38]. Thus, quasi real time pricing is generally implemented, and can effectively mobilize the users' DR to real time pricing. Quasi real time pricing means that, the time interval division and price scheme of 24 h in *D* day is set based on data mastered in D - 1 days, put on execution at 0:00 in *D*, thus users can arrange their consumptions more effectively. Then, the prices corresponding to loads in each time point is:

$$\begin{cases} p_t(t) = \frac{P'_L(t)}{P_{av}} \cdot p_{av} = \alpha(t) \cdot p_{av} \\ P_{av} = \frac{1}{24} \int_0^{24} P_L(t) dt \end{cases}$$
(6)

where $p_t(t)$ is the price at time *t* with time intervals of 15 min, $P'_L(t)$ and $P_L(t)$ is the load at time *t* with time intervals of 15 min and one hour respectively, p_{av} is the single price, P_{av} is the daily average load in D - 1 day, $\alpha(t)$ is the floating rate of quasi real time pricing at time *t*.

One day is divided into 24 time intervals, and then the elastic matrix can be constructed as:

$$\begin{bmatrix} \Delta q_1/q_1 \\ \Delta q_2/q_2 \\ \dots \\ \Delta q_{24}/q_{24} \end{bmatrix} = \begin{bmatrix} \varepsilon_{11} & \varepsilon_{12} & \dots & \varepsilon_{124} \\ \varepsilon_{21} & \varepsilon_{22} & \dots & \varepsilon_{224} \\ \dots & \dots & \dots & \dots \\ \varepsilon_{241} & \varepsilon_{242} & \dots & \varepsilon_{2424} \end{bmatrix} \begin{bmatrix} \Delta p_1/p_1 \\ \Delta p_2/p_2 \\ \dots \\ \Delta p_{24}/p_{24} \end{bmatrix}$$
(7)

$$\Delta q_i = q'_i - q_i \tag{8}$$

where q'_i and q_i is the electricity consumption before and after DR of quasi real time pricing. Substitute Equation (8) into Equation (7), then:

$$\begin{bmatrix} q_1' \\ q_2' \\ \vdots \\ q_{24}' \end{bmatrix} = \begin{bmatrix} q_1 & & \\ & q_2 & \\ & & & \\ & & & q_{24} \end{bmatrix} \begin{bmatrix} \varepsilon_{11} & \varepsilon_{12} & \dots & \varepsilon_{124} \\ \varepsilon_{21} & \varepsilon_{22} & \dots & \varepsilon_{224} \\ \vdots & \vdots & \ddots & \vdots & \vdots \\ \varepsilon_{241} & \varepsilon_{242} & \dots & \varepsilon_{2424} \end{bmatrix} \begin{bmatrix} \Delta p_1 / p_1 \\ \Delta p_2 / p_2 \\ \vdots \\ \Delta p_{24} / p_{24} \end{bmatrix} + \begin{bmatrix} q_1 \\ q_2 \\ \vdots \\ q_{24} \end{bmatrix}$$
(9)

Based on the definition of quasi real time pricing, there is:

$$\begin{cases} p_i = p_{av} \\ \Delta p_i = (\alpha - 1) p_{av} \end{cases}$$
(10)

Substitute Equation (10) into Equation (9), then:

$$\begin{bmatrix} q_1' \\ q_2' \\ \vdots \\ q_{24}' \end{bmatrix} = \begin{bmatrix} q_1 \\ q_2 \\ \vdots \\ q_{24} \end{bmatrix} \begin{bmatrix} \varepsilon_{11} & \varepsilon_{12} & \ldots & \varepsilon_{124} \\ \varepsilon_{21} & \varepsilon_{22} & \ldots & \varepsilon_{224} \\ \vdots \\ \varepsilon_{241} & \varepsilon_{242} & \ldots & \varepsilon_{2424} \end{bmatrix} \begin{bmatrix} \alpha_1 - 1 \\ \alpha_2 - 1 \\ \vdots \\ \alpha_{24} - 1 \end{bmatrix} + \begin{bmatrix} q_1 \\ q_2 \\ \vdots \\ q_{24} \end{bmatrix}$$
(11)

The elastic coefficient in the elastic matrix can be obtained by using the relevant historical electricity consumption and the historical electricity price coefficient of the power supply department, or the data obtained from the user survey. Then, we can obtain the load curve before and after DR with the implement of quasi real time pricing, and the influence of quasi real time on the BESS optimal configuration can be analyzed through the multi-objectives model proposed in this paper.

Given the BESS configuration is made at the planning stage of PV-MG, so it demands less on real-time performance and TOU is the most principle DR project implemented. Thus, this paper explores the DR's influence on BESS configuration under TOU price scenario. Then, the following formula can be constructed:

$$\begin{bmatrix} \Delta q_p / q_p \\ \Delta q_f / q_f \\ \Delta q_v / q_v \end{bmatrix} = \begin{bmatrix} \varepsilon_{pp} & \varepsilon_{pf} & \varepsilon_{pv} \\ \varepsilon_{fp} & \varepsilon_{ff} & \varepsilon_{fv} \\ \varepsilon_{vp} & \varepsilon_{vf} & \varepsilon_{vv} \end{bmatrix} \begin{bmatrix} \Delta p_p / p_0 \\ \Delta p_f / p_0 \\ \Delta p_v / p_0 \end{bmatrix}$$
(12)

Set the flat price as reference value, and simplify the parameters in Equation (6). Δp_{pf} represents the difference between peak and flat price instead of Δp_p , Δp_{vf} represents the difference between valley and flat price instead of Δp_v , and set $\Delta p_f = 0$ for simplification. Then, it can be constructed as:

$$\begin{bmatrix} \Delta q_p / q_p \\ \Delta q_f / q_f \\ \Delta q_v / q_v \end{bmatrix} = \begin{bmatrix} \varepsilon_{pp} & \varepsilon_{pf} & \varepsilon_{pv} \\ \varepsilon_{fp} & \varepsilon_{ff} & \varepsilon_{fv} \\ \varepsilon_{vf} & \varepsilon_{vp} & \varepsilon_{vv} \end{bmatrix} \begin{bmatrix} \Delta p_{pf} / p_0 \\ 0 \\ \Delta p_{vf} / p_0 \end{bmatrix}$$
(13)

In order to simplify the problem, this paper assumes that electricity consumption only shits before and after TOU power price, and the total electric quantity will stay constant. The reduced electricity consumption in peak price period can be transferred to flat and valley price period:

$$\frac{\Delta q_p}{q_p} = \varepsilon_{pp} \cdot \frac{\Delta p_{pf}}{p_0} + \varepsilon_{pv} \cdot \frac{\Delta p_{vf}}{p_0} = -\left(-\varepsilon_{pp} - \varepsilon_{pv}\right) \cdot \frac{\Delta p_{pf}}{p_0} - \varepsilon_{pv} \cdot \frac{\Delta p_{pv}}{p_0} \tag{14}$$

Equation (13) can be expressed as:

$$\Delta q_p = -K_{pf} \cdot \frac{\Delta p_{pf}}{p_0} \cdot q_p - K_{pv} \cdot \frac{\Delta p_{pv}}{p_0} \cdot q_p \tag{15}$$

where $K_{pf} = -\varepsilon_{pp} - \varepsilon_{pv}$, $K_{pv} = \varepsilon_{pv} = \varepsilon_{vp}$, $K_{pf} \cdot \frac{\Delta p_{pf}}{p_0} \cdot q_p$ is the electricity consumption transferred from peak to flat period, $K_{pv} \cdot \frac{\Delta p_{pv}}{p_0} \cdot q_p$ is the electricity consumption transferred from peak to valley period.

Simultaneously, the electricity consumption increased in flat price period increased is from the peak period, and part of the load is transferred to the valley price period.

$$\Delta q_f = K_{pf} \cdot \frac{\Delta p_{pf}}{p_0} \cdot q_p - K_{fv} \cdot \frac{\Delta p_{fv}}{p_0} \cdot q_f \tag{16}$$

$$\Delta q_v = K_{pv} \cdot \frac{\Delta p_{pv}}{p_0} \cdot q_v + K_{fv} \cdot \frac{\Delta p_{fv}}{p_0} \cdot q_v \tag{17}$$

where $K_{fv} = (-\varepsilon_{vp} - \varepsilon_{vv})$.

According to consumer psychology, the users have minimum and maximum value of electricity price, namely the lower and upper limit of threshold. When the price is lower than the minimum threshold, users won't respond to price, and when price is higher than the maximum threshold, they

will also not further respond to the upper price. Based on this, the transfer rate can be modified as follow:

$$\lambda_{pv} = \begin{cases} 0 & 0 \le \Delta p \le \Delta p_{\min} \\ K_{pv} \left(\Delta p - \Delta p_{\min} \right) & \Delta p_{\min} \le \Delta p \le \Delta p_{\max} \\ \lambda_{pv \max} & \Delta p_{\max} \le \Delta p \end{cases}$$
(18)

$$\lambda_{pv} = \begin{cases} 0 & 0 \le \Delta p \le \Delta p_{\min} \\ K_{pf} \left(\Delta p - \Delta p_{\min} \right) & \Delta p_{\min} \le \Delta p \le \Delta p_{\max} \\ \lambda_{pf \max} & \Delta p_{\max} \le \Delta p \end{cases}$$
(19)

$$\lambda_{fv} = \begin{cases} 0 & 0 \le \Delta p \le \Delta p_{\min} \\ K_{fv} \left(\Delta p - \Delta p_{\min} \right) & \Delta p_{\min} \le \Delta p \le \Delta p_{\max} \\ \lambda_{fv \max} & \Delta p_{\max} \le \Delta p \end{cases}$$
(20)

where $\lambda_{pv} = K_{pv} \cdot \frac{\Delta p_{pv}}{p_0}$, $\lambda_{fv} = K_{fv} \cdot \frac{\Delta p_{fv}}{p_0}$, $\lambda_{pf} = K_{pf} \cdot \frac{\Delta p_{pf}}{p_0}$, p_0 is taken as the reference value 1. Thus the loads in peak, valley and flat price period after the application of TOU power price

Thus the loads in peak, valley and flat price period after the application of TOU power price strategy are:

$$L_{p1,t} = L_{p0,t} - \lambda_{pv} \bar{L}_{p0} - \lambda_{pf} \bar{L}_{p0}$$
(21)

$$L_{v1,t} = L_{v0,t} + \lambda_{pv} \bar{L}_{p0} \cdot \frac{n_p}{n_v} + \lambda_{fv} \bar{L}_{f0} \cdot \frac{n_f}{n_v}$$
(22)

$$L_{f1,t} = L_{f0,t} + \lambda_{pv} \bar{L}_{p0} \cdot \frac{n_p}{n_f} - \lambda_{fv} \bar{L}_{f0}$$
⁽²³⁾

4. Joint Operation of PV-MG

4.1. Operation Strategy of PV-MG

DR and BESS system can alter the load distribution, and further affect the optimal operation of PV-MG's scheduling. The operation of PV-MG is shown in Figure 3. The BESS capacity which is configured for meeting expected stable running time of island PV-MG is called rigid capacity Q_{RC} , and when the remaining BESS capacity equals to the rigid capacity the state of charge (SOC) of storage is set at M, and the upper and lower limits of SOC are SOC_{max} and SOC_{min} separately. The BESS capacity which is configured for promoting PV consumptive rate of PV-MG is called flexible capacity Q_{FC} . Then, the total BESS capacity Q_B is:

$$Q_B = Q_{RC} + Q_{RC} \tag{24}$$

- (1) When PV output is greater than the load, Case 1: during the peak period of electricity price, PV preferentially supply electricity for local loads, and the redundant PV is supplied for BESS battery charging; Case 2: during the peak period of electricity price and BESS has been fully charged, the redundant PV will be fed in distribution power network. Case 3: during the valley period of electricity price and the SOC of BESS hasn't reached the rated value, the redundant PV and major network jointly supply power to charge BESS; Case 4: during the valley period of electricity price and BESS has been fully charged, the redundant PV is feed in distribution power network. Case 5: during the flat period of electricity price, the BESS doesn't charge or discharge, and redundant PV is feed in distribution power network.
- (2) When PV output is less than local loads Case 6: during the peak period of electricity price, SOC of BESS is greater than value M, and PV, BESS as well as the major grid supply electricity for local loads together; Case 7: in case 6, when SOC of BESS is less than the value M, PV and the

major grid jointly supply electricity for local loads. Case 8: during the valley period of electricity price, SOC of BESS hasn't reached the rated value, PV as well as the distribution network supply power for local loads, and the major network supplies power to charge BESS; Case 9: during the valley period of electricity price, when BESS has been fully charged, PV and the major network supply power for local loads; Case 10: during the flat period of electricity price, the BESS doesn't charge or discharge, and PV as well as the major network supply power for local loads.



Figure 3. The flow chart of energy exchange strategy in island micro-grid.

4.2. Analysis of System Power Balance

Complex control strategies and discrete operation state of BESS make it more complex for the implementation of optimization strategy in PV-MG. Thus, this paper adopts simple charge and discharge strategy of BESS to promote the implement and expansion of optimization strategy. Through comprehensive analysis on the characteristics of PV output, load and BESS as well as TOU price, the power balance situation of PV-MG during each moment can be described as:

(1) If *SOC* < *SOC*_{max}, and the distribution network supply electricity power to charge the BESS, that is,

$$P_{grid}(t) = P_L(t) + P_c(t)$$
⁽²⁵⁾

If $SOC > SOC_{max}$, the bulk power system only supplies electricity power to loads, that is

$$P_{grid}(t) = P_L(t) \tag{26}$$

(2) During the peak price period in the morning, the total power of PV generation is less than the demand of load power. If BESS is featured with $SOC < SOC_{min}$, the electricity power gaps is met by bulk power system, namely

$$P_{grid}(t) = P_L(t) - P_{PV}(t)\eta_{PV}$$
⁽²⁷⁾

When BESS is featured with $SOC > SOC_{min}$, the electricity power gap is met by BESS. In view of the energy storage discharge efficiency, discharge power of energy storage is:

$$P_{dc}(t) = [P_L(t) - P_{PV}(t)\eta_{PV}]/\eta_{dc}$$
(28)

Besides, the limit of depth of discharge (DOD) should be considered, and generally SOC_{min} is set as 20% of the battery capacity, then:

$$E_{\rm S}(t+1) = E_{\rm S}(t) - P_{\rm ESS}(t)\eta_{dc}\Delta t \tag{29}$$

When DOD exceeds the limit, the discharge power should be corrected as

$$\Delta P_{\text{ESS}}(t) = [E_S(t) - 0.2E_N] / \eta_{dc} \Delta t - P_{dc}(t)$$
(30)

Then, the discharge power of BESS after correction is:

$$P'_{dc}(t) = P_{ESS}(t) + \Delta P_{ESS}(t)$$
(31)

The existing power gaps exist will be met by power grid, and this electricity power is equal to the discharge power correction value, namely:

$$P_{grid}(t) = -\Delta P_{ESS}(t) \tag{32}$$

(3) When the PV output is greater than local loads,

$$P_{PV}(t) > P_L(t) \tag{33}$$

BESS is featured with $SOC > SOC_{max}$, and the excess part of PV generation is supplied for bulk power system, that is

$$P_{grid}(t) = -(P_{PV}(t) - P_L(t) - P_c(t))$$
(34)

On the contrary, if $SOC < SOC_{max}$, the redundant PV generation is supplied to charge BESS, that is:

$$P_{PV}(t) = P_L(t) + P_c(t)$$
(35)

In this occasion, the charging power should be subjected to SOC of BESS, so whether the power between the time period of t to t + 1 will excess the SOC limit should be calculated, and the charging limit of SOC is generally 0.9. Based on the battery capacity value $E_s(t)$ at time, it can be obtained that the battery capacity at time t + 1 should meet:

$$E_{S}(t+1) = E_{S}(t) + \eta_{c} \int_{t}^{t+1} P_{c}(t) dt \le 0.9E_{N}$$
(36)

If the requirement of Equation (29) is met, the charging power is:

$$P_c(t) = P_{ESS}(t) \tag{37}$$

If not, the charging power should be corrected as

$$\Delta P_{\text{ESS}}(t) = [E_{\text{N}} - E_{S}(t)] / \eta_{c} \Delta t - P_{c}(t)$$
(38)

Then, the discharge power of BESS after correction is:

$$P_c'(t) = P_c(t) + \Delta P_{ESS}(t)$$
(39)

The redundant PV power can only flow into power grid, and it's the charging power correction value of BESS, namely:

$$P_{grid}(t) = -\Delta P_{ESS}(t) \tag{40}$$

$$P_e(t) = \begin{cases} 0 & P_{grid} \ge 0\\ P_{grid}(t) & P_{grid}(t) < 0 \end{cases}$$
(41)

$$P_i(t) = \begin{cases} P_{grid}(t) & P_{grid} \ge 0\\ 0 & P_{grid}(t) < 0 \end{cases}$$
(42)

According to the analysis above, the battery storage system charge and discharge twice in one typical day under TOU price. Due to the progress of charging and discharging cycle, the available battery storage capacity gradually reduces. The battery storage capacity retention ratio is actually the ratio of practical capacity to rated capacity. In addition, the demarcation point of availability of BESS is usually taken as $70\% \sim 80\%$. If the BESS is lithium battery, then its serve life is 3000 times. Based on 260 typical similar days in one year, the service life of PV-MG is 15 years. Thus the BESS system needs once replacement within operation period.

5. Investment and Benefit Model of PV-MG

5.1. Annual Investment of PV-MG

The annual investment of PV-MG includes the PV system, BESS, BESS bidirectional converter module and operation maintenance cost. The PV system cost is the total cost of PV panel and its PV inverter. The maintenance contains the reasonable expenditure of maintenance, management, labor and related upgrading and transformation [39].

$$CI = C_{PV} + C_B + C_C \tag{43}$$

$$C_{PV} = Q_{PV} \cdot \left(I_{PV} \cdot \frac{r_0 (1+r_0)^m}{(1+r_0)^m - 1} \right) + u(A)$$
(44)

$$C_B = Q_B \cdot \left(I_B \cdot R_E \frac{r_0 (1+r_0)^m}{(1+r_0)^m - 1} \right) + u(B)$$
(45)

$$C_C = P_I \cdot \left(I_I \cdot \frac{r_0 (1+r_0)^m}{(1+r_0)^m - 1} \right) + u(C)$$
(46)

where u(A), u(B), u(C) and are the operation and maintenance cost of PV system, BESS module, and BESS inverter module separately, which are calculated as the proportion of 0.3% of construction costs; r_0 is discount rate of 0.04 in this paper.

5.2. Annual Income of PV-MG

The income of PV-MG includes three parts. The first one is earnings for power selling, which comes from the electricity supplied to local loads. The second one is network power price, which comes from selling extra electricity of MG to distribution network, and the last is subsidy income,

which is supplied by nation or local government to PV system to promote its development. Then the daily income of PV-based income *CO* is:

$$CO = \sum_{t=1}^{T} \left(e_L(t) P_L(t) + e_e P_e(t) - e_i(t) P_i(t) + e_{pv} P_{pv}(t) \right) \Delta t$$
(47)

This paper assumes that the price of user price is equal to electricity price of MG purchased from distribution network, namely $e_d = e_i$.

5.3. Net Profits and PV Consumptive Rate

Annual net profits of PV-MG C_{net} is

$$C_{net} = CO \times R - CI \tag{48}$$

where *R* is the number of similar days. Considering the weather effect, the net profits of 260 similar days can equal to that of one year in this paper.

Photovoltaic consumptive rate S_{PV} is expressed as:

$$S_{PV} = \frac{E_{SC} + E_{FC}}{\sum_{t=1}^{T} P_{PV}(t)} \times 100\%$$
(49)

$$E_{SC} = \sum_{i=1}^{T} \min \left\{ P_{pv}(t), P_L(t) \right\}$$
(50)

6. Multi-Objective Optimization Optimal Sizing Model and Solution

6.1. Objective Function

In the demand response based multi-objective capacity optimal sizing model of battery storage in PV-MG, the annual net profits and photovoltaic consumptive rate are selected as the dual optimization objectives-, shown as:

$$\max \mathbf{Y} = \max \left[C_{net}, S_{PV} \right]$$

s.t. $h(\mathbf{x}) = 0$
 $g(\mathbf{x}) \le 0$
 $u_{\min} \le u \le u_{\max}$ (51)

where *Y* is the objective function vector, *x* is decision variable, *h*, *g* is the equality and inequality constraints separately. *u* is the decision variable dimension with its upper and lower limit of u_{max} and u_{min} separately. In this paper, the decision variable is the capacity of BESS.

6.2. Constraint Conditions

(1) Reliability constraints of PV-MG

In order to ensure the stable operation time in off-grid operation of PV-MG:

$$Q_B \ge Q_{RC.\,\min} \tag{52}$$

(2) BESS performance constraints

BESS performance constraints mainly include charge and discharge power constraint, charge and discharge status constraint, BESS capacity constraint and so on. Combining with [40], the charge and discharge model expression of BESS can be described as:

$$\begin{cases} E_{s} (t + \Delta t) = E_{s}(t) + \varepsilon_{c} P_{c}(t) \Delta t \cdot \eta_{c} - \varepsilon_{dc} P_{dc}(t) \Delta t / \eta_{dc} \\ SOC (t + \Delta t) = [E_{s}(t) + \Delta E_{s}(t)] / E_{N} \\ SOC_{\min} \leq SOC \leq SOC_{\max} \\ \sum_{t=1}^{T} \eta_{c} P_{c} \Delta t = \sum_{t=1}^{T} \frac{P_{dc}}{\eta_{dc}} \Delta t \\ DOD \leq 0.8 \\ \eta_{c} + \eta_{dc} = 1, \eta_{c}, \eta_{dc} \in \{0, 1\} \end{cases}$$
(53)

where ε_c and ε_{dc} are binary numbers which means the BESS charge or discharge, and one of ε_c and ε_{dc} must be 1. Number 1 of ε_c means the charge status of BESS. *DOD* is the depth of discharge of BESS. $\Delta E_s(t)$ is the battery capacity value difference between the current time and the previous time. This paper makes assumption that BESS system completes a charge and discharge cycle in one typical day *T*, which means the SOC of BESS at the end of the day should be the same as the beginning.

(3) Users' purchasing electricity cost constraint

Users' purchasing electricity cost constraint means that, the purchasing electricity cost after multi-period demand response, otherwise, users won't respond to TOU price.

$$E_I \le e_0 \sum_{t \in T} P_L(t) \tag{54}$$

$$E_{I} = \sum_{t \in T_{f}} e_{f} P_{L}(t) + \sum_{t \in T_{p}} e_{p} P_{L}(t) + \sum_{t \in T_{g}} e_{g} P_{L}(t)$$
(55)

where E_I is the purchasing electricity cost under peak-valley TOU price; e_0, e_f, e_p, e_g are single price, peak period price, flat period price and valley period price separately; T_f, T_p, T_g are peak period, flat period and valley period respectively.

6.3. Model Solution

Comprehensively considering factors, such as PV output, BESS charge and discharge characteristic, loads and TOU price, the upper and lower limit of decision variables can be decided. Besides, based on the multi-joint scheduling operation strategy of PV-MG, this paper plans to adopt the NSGA-II algorithm to solve the demand response based multi-objective capacity optimal sizing model of BESS. NSGA-II algorithm is proposed by Deb et al. based on the improvement of NSGA algorithm [41,42]. It is one of the multi-objective evolutionary algorithms with high accreditation degree.

The process of the BESS optimal sizing by NSGA-II is shown in Figure 4. The left side is the NSGA-II algorithm process, and the right side is the double objectives of net profits and PV consumptive rate, whose results iterate in the NSGA-II algorithm process.

The flow chart in Figure 4 can be described as:

- (1) Code: Determine the map from phenotype to genotype.
- (2) Generate the initial population: Evolutionary counter is set to zero, and individuals are randomly generated. Each string structure represents one individual, and all the individuals make for one population.
- (3) Determine quantitative method for the individual fitness: The conversion rule from the value of objective function to the degree of fitness, which indicates the advantages and disadvantages of the individual.
- (4) Stratification: Non-dominant hierarchical approach is used to make sure that, the superior individuals have greater chance of inheritance to the next generation, and the fitness sharing strategy to maintain population diversity. The specific features are:

- (i) As for the rapid non-dominated sorting method based on classification, the computational complexity is $O(mN^2)$ (Where m is the number of objective functions, and N is the number of individuals in population)
- (ii) The concept of crowding distance is proposed to indicate fitness value of different elements after fast non-dominated sorting, so that the individuals in current Pareto front can be extended throughout the Pareto frontier as evenly as possible, and the time complexity of crowding distance is O(m(2N)log(2N));
- (iii) Elitist mechanism is introduced.Offspring individuals compete with their parent individuals to generate the next generation population, which can improve the overall level of population evolution.
- (5) Selection, crossover, variation: Retain individuals with high degree of adaptability according to their fitness. Crossover operator is applied to the group, and individuals are selected by crossover and mutation probability to generate new individuals.
- (6) Calculate objective functions, and the best individuals are selected to carry on the next step.



Figure 4. The process of battery energy storage system (BESS) optimal sizing by non-dominated sorting genetic algorithm II (NSGA-II).

The multi-objective optimization results of NSGA-II algorithm are one set of solutions, which is called non-dominated solution or Pareto optimal solution. Introduction of the non-dominated sorting strategy, elitist keep technology, sun-crowding comparison operators and other technologies makes the scope and efficiency of the NSGA-II algorithm expanded and improved, and the distribution of non-dominated solutions more uniform and diverse.

7. Case Study

7.1. Basic Data

This paper chooses a PV-MG in Guangdong province of China as the object of study, and its basic electrical topology is shown in Figure 5. The electricity price, PV output and loads in the model are all taken from actual users. Therefore, their distribution within the optimization target time domain is determined. Capacity and load of PV system for each power user are shown in Table 2. The component parameters in PV-MG are shown in Table 3. In addition, the PV output, original loads and net loads of different users are shown in Figures 6–8 respectively.



Figure 5. Basic electrical topology of PV-MG.

Table 2. The profiles of users in the microgrid (MG).

User	PV Capacity (kW)	Peak Load (kW)
User-1	550	505.22
User-2	500	431.87
User-3	400	349.44
User-4	400	357.54
User-5	250	213.76

System Parameters	Value
PV module price/($\times 10^3$ \$/kW)	1.27
PV converter efficiency	0.97
Battery storage price/($\times 10^3$ \$/kWh)	0.74
Battery storage efficiency	0.96
Battery inverter price/($\times 10^3$ \$/kW)	0.9
Battery inverter efficiency	0.96
Battery storage lifetime(times)	3000
PV array lifetime(year)	20

Table 3. Parameters of the components in the MG

600 -0 - Commercial user-1 - Commercial user-2 - Office user-1 500 ★ Office user-2 400 PV power 500 kw) 100 10 Time 12 16 (hour) 18 14

Figure 6. Distributed users' photovoltaic power (PV) power curves in a typical day.



Figure 7. Distributed users' original power curves.



Figure 8. Users' power curves of net load.

Total loads, PV output and net power curves are shown in Figure 9. As can be seen, this PV-MG is a typical commercial/office MG, the loads of which presents the characteristics of peak in day and valley at night. The peak value of both total loads and net loads is 1573 kW at 21:00. Load rate of total loads is 0.75, while that of net loads is 0.33, indicating that the PV system makes load rate less desirable. The reason is that the maximum PV output usually occurs at noon, rather than the time of peak loads. Thus, the maximum loads change slightly with PV, while the average loads are reduced due to the cancellation of PV, and the load rate becomes smaller.



Figure 9. Users' total power curves and PV output.

7.2. DR Results Analysis

In this paper, the distributed PV feed-in purchase price is 0.057 \$/kWh, and PV subsidy price is 0.063 \$/kWh. The prices of electricity bought from power grid and sold to users are measured under the same TOU price, as shown in Table 4. The single electricity price before the implementation of TOU price is 0.075 \$/kWh.

Туре	Periods	Electricity Price (\$/kWh)
Peak price	10:00-15:00 17:00-22:00	0.12
Flat price	07:00-10:00 15:00-17:00 22:00-24:00	0.09
Valley price	00:00-07:00	0.045

Table 4. time-of-use (TOU) power price.

In real market, the supply curve must be obtained through detailed market research and statistical analysis. Based on the demand elasticity coefficient in [43], the electricity price elasticity curve parameters are shown in Table 5.

Table 5. Parameters of electricity price relation curve.

Parameters	Peak Period	Flat Period	Valley Period
(a_i, b_i)	(6.5, 65)	(5.0, 60)	(4.0, 58)

Then, the electricity price elasticity matrix is:

	-0.0870	0.0502	0.0201
E =	0.0912	-0.0526	0.0211
	0.0915	0.0528	-0.0211

As shown in Figure 10, peak-valley difference of loads after DR has been reduced, and the load curve has become smoother. As shown in Table 6, the peak-valley difference reduces from 815.4 kW to 649.3 kW after DR, which achieves the effect of peak load shifting. PV consumptive rate reduces from 46.39% to 45.25% after DR. It can be explained that the maximum PV output occurs at noon. However, the loads at daily peak period have been reduced after DR, and the instant PV electricity consumption is decreased.



Figure 10. Daily load curve of before and after DR.

Table 6. Load characters of before and after demand response (DR).

Туре	Peak value/kW	Valley value/kW	Peak-Valley Difference/kW	PV Consumptive Rate
Before DR	1573	757.9	815.1	46.39%
After DR	1492	842.7	649.3	45.25%

7.3. BESS Optimal Sizing Result Analysis

- 7.3.1. Rigid BESS Capacity Optimal Sizing
- (1) Rigid battery storage capacity optimal sizing

This paper considers the extreme operation situation of PV-MG for the rigid battery storage capacity optimal sizing, which means that, the rigid battery storage should guarantee the important loads operating for 0.5 h without PV output and distribution network electricity support. The important loads in this study case account for 20% of total loads, so the peak values of important loads are 314.6 kW and 298.4 kW respectively before and after DR. Thus, the rigid battery storage capacity should be at least 157.3 kWh and 149.2 kWh respectively. The energy conversion efficiency of BESS is 0.92, and DOD of BESS should be more than 0.8. Thus the actual rigid battery storage capacity should be separately at least 213.7 kWh and 202.7 kWh before and after DR.

(2) Storage converter optimal sizing

In order to meet the requirements of shock loads in PV-MG, which is 389 kW in this case, the short-term overload coefficient of bidirectional inverter is 1.2, and the rated power of selected storage bidirectional converter should be at least 324 kW.

7.3.2. Flexible BESS Capacity Optimal Sizing

NSGA-II algorithm is utilized to solve the optimization model. In this paper, population quantity is set as 50, the maximum iterations as 100 times, crossing-over rate as 0.9 and aberration rate as 0.1. In the DR based multi-objective BESS capacity optimal sizing model, the multi-objectives are annual net profits and PV consumptive rate of PV-MG, and the decision variable is flexible BESS capacity. Based on the load curves before and after DR, the Pareto frontier is shown in Figure 11.



Figure 11. The result of Pareto front by NSGA-II.

The Pareto frontier obtained from NSGA-II algorithm can provide significant messages for the two compromise selected opposite objectives of improving net benefit and PV consumptive rate. As the actual net profits of PV-MG is negative, reduction of system losses can be interpreted as improvement of net profits. The flexible BESS capacity optimal sizing results and their corresponding net profits under different PV consumptive rate goals before and after DR are shown in Table 7.

Type	Optimal Parameters	PV Consumptive Rate			
Type	optimier i urumeters	88% 90% 9		92%	
	Flexible BESS (kWh)	255.6	426.8	585	
Defers DD	Rigid BESS (kWh)	213.7	213.7	213.7	
Delote DK	BESS total capacity (kWh)	469.3	640.5	798.7	
	Net profits ($\times 10^4$ \$)	-38.61	-41.82	-59.79	
	Flexible BESS (kWh)	424.6	583.2	734.1	
After DR	Rigid BESS (kWh)	202.7	202.7	202.7	
	BESS total capacity (kWh)	627.3	785.9	936.8	
	Net profits $(\times 10^4\$)$	-42.02	-44.98	47.82	

Table 7. Energy capacity optimization of before and after DR.

As shown in Table 7:

- (1) After the implementation of peak-valley TOU price, peak-valley difference has reduced. Thus, the rigid BESS capacity, which is configured to guarantee the important loads operating for 0.5 h, can be reduced after DR.
- (2) BESS cost is still relatively expensive at present, and the rigid BESS utilized to ensure the reliability of the system is relatively large., Thus the net profits of PV-MG will be negative when only Figure d with rigid BESS, which will be further reduced with the increase of flexible BESS capacity.
- (3) Since the PV consumptive rate is decreased after DR, more capacity of flexible BESS should be configured to achieve the same PV consumptive rate goal.

7.3.3. Sensitivity Analysis of BESS Subsidies

On the whole, after the optimal sizing of the BESS, the PV-MG does not generate direct economic benefits. However, system power supply reliability benefits and environmental benefits brought through BESS optimal sizing are significant. Therefore, BESS optimal sizing in PV-MG is necessary. Besides, the cost of lithium batteries and storage converter modules have been showing downward trend.

In addition, BESS possesses potential subsidies to make reasonable compensation for PV-MG investment costs, such as the subsidies for the investment capacity, the charge and discharge capacity, and certain fiscal and tax preferential policies. This paper assumes that the BESS (including the energy storage battery and the energy storage converter) is subsidized as the investment capacity, and the subsidy investment accounts for 20%–40% of its fixed investment cost. This paper analyzes the influence of the increase of BESS subsidy proportion on the net benefit of PV-MG before and after DR, the results of which are shown in Table 8.

	BESS Subsidy Proportion	Net Profits (×10 ³ \$)		
	2200 0400149 110 portion	S _{PV} = 88%	$S_{PV}=90\%$	$S_{PV}=92\%$
Before DR	20% 40% 60%	-256.9 -129.4 -2.1	$-263.4 \\ -110.7 \\ 41.9$	-418.8 -242.8 -66.7
After DR	20% 40% 60%	-267.3 -116.6 34.1	-273.4 -99.3 74.9	-279.4 -83.0 11.4

Table 8. The summary of sensitivity analysis.

As shown in Table 8, under the situation that electricity price, PV module cost, PV consumptive rate and other conditions are invariable, net profits of PV-MG will grow in linear relationship with

BESS subsidy, and can be positive within a certain range. This indicates that of the economical efficiency of PV-MG after BESS optimal sizing has been improved.

8. Conclusions

Research on the impact of DR on BESS optimal sizing has a significant effect on commercial investment decisions of PV-MG. This paper established multi-period DR model based on price elasticity matrix under TOU price. Besides, the DR and BESS system operation are included into PV-MG scheduling optimization to build the MG investment profit model. Considering the constraint conditions such as power supply and demand balance, side electricity price elasticity, loss of BESS systems, the PV consumptive rate and annual net profits are taken as greatest objectives to utilize NSGA-II algorithm to solve the DR-based BESS capacity optimize optimal sizing model in PV-MG.

Simulation results show that, in the electricity market environment, the needed rigid BESS capacity and PV consumptive rate decrease after DR. Thus, more capacity of flexible BESS should be configure d to contribute the midday PV consumption and achieve the same PV consumptive rate goal. This paper applies an optimization method to a practical MG in Guangdong to verify the reasonability of the proposed model and algorithm, which can be a significant reference on commercial investment decisions of PV-MG.

In order to solve the influence of uncertain PV on the stable operation of PV-MG, DR and BESS are introduced simultaneously into the operation optimal scheduling of PV-MG, and the uncertainties PV can be suppressed so as to improve the PV consumptive level, which is of great guiding significance for BESS optimal sizing under this situation. The net profits of PV-MG is poor with relatively expensive BESS module cost at present stage. With the decrease of BESS cost or further drive of the energy storage subsidy policy, business investment potential of PV-MG with BESS will be further enhanced.

Acknowledgments: This work was supported by the National High Technology Research and Development of China 863 Program (2014AA052001).

Author Contributions: Nan Zhou and Nian Liu proposed the multi-objective optimal sizing model for battery storage of PV-based microgrid with demand response. Jianhua Zhang and Jinyong Lei provided theoretical knowledge in the energy domain, also reviewed and refined the paper.

Conflicts of Interest: The authors declare no conflict of interest.

Nomenc	lature	$P_{dc}^{\prime}(t)$	Discharge power of BESS after
Р	Electricity price		correction
p_0	Single electricity price before the implement of TOU price	$P_e(t)$	Electricity exported to distribution network.
Δp_j	Variable quantity of electricity price at time period <i>i</i>	$P_i(t)$	Electricity imported from distribution network
0	Electricity consumption	P_{T}	Total power of BESS bidirectional
$\tilde{\Lambda}a$	Variable quantity of electricity	- 1	inverter
	consumption at time period i	$E_{s}(t)$	Battery capacity at time t
a,b	Power price curve parameters	E_N	Rated battery capacity
ε _{ii}	Self-elasticity coefficient	E_{SC}	Total photovoltaic electricity power
ε_{ii}	Cross-elasticity coefficient	50	consumed by local loads in one day
f, p, v	Flat, peak, valley price periods	E_{FC}	Total photovoltaic electricity power
λ_{n72}	Load transfer rates from peak to flat	10	consumed by flexible BESS
λ_{nf}	period, peak to valley period and flat	η_{PV}	PV inverter efficiency
λ_{fv}^{PJ}	to valley period separately	η_c	Charging power efficiency of BESS
L_{f0t}	Loads in peak price period before DR	η_{dc}	Discharge power efficiency of BESS
$L_{n0,t}$	Loads in flat price period before DR	CI	Annual investment of PV-MG
L_{v0t}	Loads in valley price period before DR	СО	Daily income of PV-MG
L_{f1t}	Loads in peak price period after DR	C_{PV}	Annual investment of PV system
L_{n1t}	Loads in flat price period after DR	C_B	Annual investment of battery storage
L_{a1t}	Loads in valley price period after DR	C_C	Annual investment of BESS
$\bar{L}_{f0}^{s_{1,k}}$	Average loads of peak price period		bidirectional converter module
50	before DR	C_{net}	Annual net profits of PV-MG.
\bar{L}_{p0}	Average loads of flat price period	I_{PV}	Unit price of PV system
r °	before DR	I_B	Unit price of battery storage
\bar{L}_{v0}	Average loads of valley price period	I_I	Unit price of BESS inverter module
	before DR	u(A),	Operation and maintenance cost of
n_f	Durations of peak price period	u(B),	PV system, BESS module, and BESS
n_p	Durations of flat a price period	u(C)	inverter module separately
n_v	Durations of valley price period	e_L	User price
Q_B	Total BESS capacity	e_e	PV feed-in-tariff
Q_{RC}	Rigid BESS capacity	e_i	Electricity price of MG purchased
Q_{FC}	Flexible BESS capacity		from power grid
Q_{PV}	Rated PV capacity	e_{pv}	PV subsidy price
$Q_{RC.\min}$	Minimum value of BESS rigid capacity.	S_{PV}	Time duration from the total
$P_L(t)$	Load at time <i>t</i>	Δt T	In the duration from t to $t + 1$
$P_{pv}(t)$	PV generation power at time <i>t</i>	1	Discount rate
$P_{grid}(t)$	Electricity power supplied by	r0 P	Number of similar days in one weer
- ()	distribution network at time <i>t</i>		Roplacing times of RESS
$P_c(t)$	Charging power of BESS at time <i>t</i>	NE	Replacing times of DE00
$P_{dc}(t)$	Discharge power of BESS at time t		

References

 $\Delta P_{ESS}(t)$ Power correction value of BESS

- 1. Sujil, A.; Agarwal, S.K.; Kumar, R. Centralized multi-Agent implementation for securing critical loads in PV based microgrid. *J. Mod. Power Syst. Clean Energy* **2014**, *2*, 77–86.
- 2. Gabbar, H.A.; Abdelsalam, A. Microgrid energy management in grid-connected and islanding modes based on SVC. *Energy Convers. Manag.* 2014, *86*, 964–972.
- 3. Masih-Tehrani, M.; Ha'iri-Yazdi, M.R.; Esfahanian, V. Optimum sizing and optimum energy management of a hybrid energy storage system for lithium energy life improvement. *J. Power Sources* **2013**, 244, 2–10.
- 4. Liu, W.; Niu, S.; Xu, H. Optimal planning of battery energy storage considering reliability benefit and operation strategy in active distribution system. *J. Mod. Power Syst. Clean Energy* **2016**, 1–10.
- 5. Aghamohammadi, M.R.; Abdolahinia, H. A new approach for optimal sizing of battery energy storage system for primary frequency control of islanded Microgrid. *Int. J. Electr. Power Energy Syst.* **2014**, *54*, 325–333.

- An, L.N.; Quoc-Tuan, T.; Seddik, B.; Van-Linh, N. Optimal sizing of a grid-connected microgrid. In Proceedings of the IEEE International Conference on Industrial Technology, Seville, Spain, 17–19 March 2015.
- 7. Ma, X.; Chen, M.; Zhou, X. Study on the probabilistic optimal capacity of energy storage in microgrid. *Electric Power* **2015**, *48*, 131–136.
- 8. Li, B.; Chen, S.; Liang, S. A capacity optimization of energy storage system for output smoothing of photovoltaic station. *Power Syst. Protect. Control* **2014**, *22*, 45–50.
- 9. Nguyen, T.; Crow, M.L.; Elmore, A.C. Optimal sizing of a vanadium redox battery system for microgrid systems. *IEEE Trans. Sustain. Energy* **2015**, *99*, 1–9.
- 10. Liu, N.; Chen, Z.; Liu, J.; Tang, X.; Xiao, X.; Zhang, J. Multi-objective optimization for component capacity of the PV-based energy switch stations: Towards benefit of economy and environment. *Energy* **2014**, *64*, 779–792.
- 11. Ma, L.; Liu, N.; Wang, L.; Zhang, J.; Lei, J. Multi-party energy management for smart building cluster with PV systems using automatic demand response. *Energy Build.* **2016**, *121*, 11–21.
- 12. Mazidi, M.; Zakariaziadeh, A.; Jadidi, S.; Siano, P. Integrated scheduling of renewable generation and demand response programs in a microgrid. *Energy Convers. Manag.* **2014**, *86*, 1118–1127.
- 13. Rivarolo, M.; Greco, A.; Massardo, A.F. Thermo-economic optimization of the impact of renewable generators on poly-generation smart-grids including hot thermal storage. *Energy Convers. Manag.* **2013**, *65*, 75–83.
- Costabeber, A.; Tenti, P.; Mattavelli, P. Distributed cooperative control of low-voltage residential microgrids. In Proceedings of the 2012 3rd IEEE International Symposium on Power Electronics for Distributed Generation Systems (PEDG), Aalborg, Denmark, 25–28 June 2012; pp. 457–463.
- 15. Gouveia, C.; Moreira, J.; Moreira, C.L.; Lopes, J. Coordinating storage and demand response for microgrid emergency operation. *IEEE Trans. Smart Grid* **2013**, *4*, 1898–1908.
- 16. Bui, V.H.; Kim, H.M.; Song, N.O. Applying demand response based on TOU and EDRP to optimal microgrid operation. *Int. J. Smart Home* **2015**, *9*, 41–50.
- 17. Nisar, A.; Thomas, M.S. Comprehensive control for microgrid autonomous operation with demand response. *IEEE Trans. Smart Grid* 2016, 1–9.
- Koohi-Kamali, S.; Rahim, N.A.; Mokhlis, H. New algorithms to size and protect battery energy storage plant in smart microgrid considering intermittency in load and generation. In Proceedings of the IET International Conference on Clean Energy and Technology, Kuching, Malaysia, 24–26 November 2014; pp. 1–7.
- 19. Kerdphol, T.; Qudaih, Y.; Mitani, Y. Optimal battery energy storage size using particle swarm optimization for microgrid system. *Int. Rev. Electr. Eng.* **2015**, *10*, 2.
- 20. Zhao, B.; Bao, K.; Xu, Z.; Zhang, Y. Optimal sizing for grid-connected PV-and-storage microgrid considering demand response. *Proc. CSEE* 2015, *35*, 5465–5474.
- 21. Sharma, S.; Bhattacharjee, S.; Bhattacharya, A.A. Grey wolf optimisation for optimal sizing of battery energy storage device to minimise operation cost of microgrid. *IET Gener. Trans. Distrib.* **2016**, *10*, 625–637.
- Kerdphol, T.; Tripathi, R.N.; Hanamoto, T.; Khairudin. ANN based optimized battery energy storage system size and loss analysis for distributed energy storage location in PV-microgrid. In Proceedings of the 2015 IEEE Innovative Smart Grid Technologies—Asia (ISGT ASIA), Bangkok, Thailand, 3–6 November 2015.
- Sahebi, M.M.; Duki, E.A.; Kia, M.; Soroudi, A. Simultanous emergency demand response programming and unit commitment programming in comparison with interruptible load contracts. *IET Gener. Trans. Distrib.* 2012, 6, 605–611.
- 24. Ruan, W.; Wang, B.; Li, Y. Customer response behavior in time-of-use price. *Power Syst. Technol.* **2012**, *36*, 86–93.
- 25. Daniel, S.K.; Goran, S. Factoring the elasticity of demand in electricity prices. *IEEE Trans. Power Syst.* 2000, 15, 612–617.
- 26. Liu, Y.; Liu, J.; Tang, J. An optimal decision-making model for power supply company power purchase in weekly market considering price elasticity matrix of demand side and risk. *Power Syst. Technol.* **2008**, *18*, 18–24.

- 27. Bushnell, J.B.; Mansur, E. *The Impact of Retail Rate Deregulation on Electricity Consumption in San Diego*; University of California Energy Institute: Berkeley, CA, USA, 2001.
- 28. Liu, N.; Zou, F.; Wang, L.; Wang, C.; Chen, Z. Online energy management of PV-assisted charging station under time-of-use pricing. *Electr. Power Syst. Res.* **2016**, *137*, 76–85.
- 29. Ding, Y.; Decker, C.; Vassileva, I.; Wallin, F. A smart energy system: distributed resource management, control and optimization. In Proceedings of the IEEE PES International Conference and Exhibition on Innovative Smart Grid Technologies, Manchester, UK, 5–7 December 2011; pp. 1–8.
- 30. Liu, N.; Tang, Q.; Zhang, J.; Fan, W.; Liu, J. A hybrid forecasting model with parameter optimization for short-term load forecasting of micro-grids. *Appl. Energy* **2014**, *129*, 336–345.
- Lu, C.; Raghunathan, V.; Roy, K. Maximum power point considerations in micro-scale solar energy harvesting systems. In Proceedings of the 2010 IEEE International Symposium on Circuits and Systems (ISCAS), Paris, France, 30 May–2 June 2010; pp. 273–276.
- 32. Kim, K.; Yoon, T.; Byeon, G.; Jung, H.; Kim, H. Power demand and power quality analysis of EV charging station using BESS in microgrid. In Proceedings of the Vehicle Power and Propulsion Conference, Seoul, Korea, 9–12 October 2012; pp. 996–1001.
- 33. Gudi, N.; Wang, L.; Devabhaktuni, V. A demand side management based simulation platform incorporating heuristic optimization for management of household appliances. *Int. J. Electr. Power Energy Syst.* **2012**, *43*, 185–193.
- Cobeo, I.; Boyra, M.; Castellanos, A. Commercial building load modeling for demand response applications. In Proceedings of the 20th International Conference and Exhibition on Electricity Distribution, Prague, Czech, 8–11 June 2009; IET: London, UK; pp. 1–4.
- 35. Ferruzzi, G.; Graditi, G.; Rossi, F.; Russo, A. Optimal operation of a residential microgrid: The role of demand side management. *Intell. Ind. Syst.* **2015**, *1*, 61–82.
- 36. Walawalkar, R.; Blumsack, S.; Apt, J.; Fernands, S. An economic welfare analysis of demand response in the PJM electricity market. *Energy Policy* **2008**, *36*, 3692–3702.
- 37. Sauer, D.U.; Wenzl, H. Comparison of different approaches for lifetime prediction of electrochemical systems-using lead-acid batteries as example. *J. Power Sources* **2008**, *176*, 534–546.
- 38. Huang, H.; Deng, L.; Wen, F.; Wang, F. Customer response behavior based on real-time pricing. *Electric Power Constr.* **2016**, *37*, 63–68.
- Dusonchet, L.; Ippolito, M.G.; Telaretti, E.; Graditi, G. Economic impact of medium-scale battery storage systems in presence of flexible electricity tariffs for end-user application. In Proceedings of the 9th International Conference on European Energy Market, Florence, Italy, 10–12 May 2012; pp. 1–5.
- Vergara, P.; Torquato, R.; Silva, L. Towards a real-time Energy Management System for a Microgrid using a multi-objective genetic algorithm. In Proceedings of the IEEE Power and Energy Society General Meeting, Denver, CO, USA, 26–30 July 2015.
- Kuznetsova, E.; Ruiz, C.; Li, Y.; Zio, E. Analysis of robust optimization for decentralized microgrid energy management under uncertainty. *Int. J. Electr. Power Energy Syst.* 2015, 64, 815–832.
- 42. Farina, M.; Amato, P. A fuzzy definition of optimality for many-criteria optimization problems. *IEEE Trans. Syst. Man Cybern.* **2004**, *34*, 315–326.
- 43. Qin, Z.; Yue, S.; Yu, Y. Price elasticity matrix of demand in current retail power market. *Automat. Electric Power Syst.* **2004**, *28*, 16–19.



© 2016 by the authors; licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC-BY) license (http://creativecommons.org/licenses/by/4.0/).